



LEGEND

S.NO.	SYMBOL	SPECIFICATION	LENGTHS
A.		300X100 POWER CABLE TRAY	
		300X75 POWER CABLE TRAY	
		300X75 POWER CABLE TRAY	

Note:

- All supply grills mounted to pelmets or partition walls to achieve +2950mm HT. for Cooling.
- Main Ducts to achieve maximum heights wherever possible
- Supply Air diffuser's to be placed on the grid ceiling in Fish & Meat Section.
- AHU Tray to be provided Only for Drain Pipe & CHWSR Pipes, no electrical wiring to be done to this tray.

1. All Levels are marked are from Retail Area Finish Floor Level.
 2. CABLE TRAYS bottom to be kept mostly approx 330mm from FFL, until & unless other services come in between due to site conditions, in that case cable trays to be bent in slope and avoid hindrances. Kindly coordinate with site vendors before installing.
 3. CABLE TRAYS TO BE made of MS/ GI & painted same as ceiling paint

TO BE CONNECTED WITH CHILLER WATER & FRESH AIR INTAKE

ENTRY EXIT