





DAIKIN
DAIKIN
vivo V21e


AIR CONDITIONER
OUTDOOR CONDENSING UNIT
MODEL RZCFQ100CV16
ISEER 3.85
50Hz 230V ~ 1P
SER. NO. 0002021
COOLING CAPACITY (100%) 10510W
COOLING CAPACITY (50%) 5255W
POWER CONSUMPTION (100%) 3360W
POWER CONSUMPTION (50%) 1300W
ELECTRICITY CONSUMPTION 2112.89 UNITS PER YEAR
REFRIGERANT (R32) 1.3kg
CURRENT 16.23A
NET WEIGHT 48.5kg
DIMENSIONS (cm LxWxH)
93.0X35.0X69.5
IS:1391(Part-2)
CM/L-8400163007
For details of BIS certification
please visit www.bis.gov.in
DAIKIN AIRCONDITIONING INDIA PVT. LTD.
MADE IN INDIA
3P778256-7G


AIR CONDITIONER OUTDOOR CONDENSING UNIT
MODEL RZCFQ100CV16
ISEER 3.85
50Hz 230V ~ 1P
SER. NO. 0002019
COOLING CAPACITY (100%) 10510 W
COOLING CAPACITY (50%) 5255 W
POWER CONSUMPTION (100%) 3360 W
POWER CONSUMPTION (50%) 1300 W
ELECTRICITY CONSUMPTION 2112.89 UNITS PER YEAR
REFRIGERANT (R32) 1.3 kg
CURRENT 16.23A
NET WEIGHT 48.5 kg
DIMENSIONS (cm LxWxH) 93.0X35.0X69.5
IS:1391(Part-2)
CM/L-8400163007
For details of BIS certification please visit www.bis.gov.in
DAIKIN AIRCONDITIONING INDIA PVT. LTD.
MADE IN INDIA
3P778256-7G


MODEL: FCFQ100CV16 SER. NO.: 0002596
DAIKIN AIRCONDITIONING INDIA PVT.LTD.
RIICO NEW INDUSTRIAL COMPLEX, NEEMRANA, RAJASTHAN, INDIA-301705
AIR CONDITIONER HEAT PUMP/COOLING ONLY
MODEL FCFQ100CV16 INDOOR UNIT
POWER SUPPLY 230 V 1~ PH 50 Hz
INPUT COOLING 225 W W
FAN MOTOR PH QTY FLA W OUT
- - - - 1 - 1.7 - 106 -
MASS 25 kg
SER. NO. 0002596
MFG. DATE September-2026
MADE IN INDIA
SCAN FOR MANUAL
IS:1391(Part-2)
CM/L-8400163007
SCAN FOR MFG
FOR DETAILS OF BIS CERTIFICATION PLEASE VISIT www.bis.gov.in
MFG:MANUFACTURING DETAIL
2P811882-1
WARNING NOTE TO SE
May cause electric shock, ignition
Before starting the inspection of the electrical parts (control b
fan motor, drain pump, etc.), be sure to cut off all the power
of indoor unit and outdoor unit, or you may get an electric s
When cleaning the heat exchanger, be sure to remove the c
box, fan motor and drain pump. Water or detergent may de
the insulation of electric components and result in burn-ou
these components.
WARNING CAUTION! ELECTRIC SHOCK
Due to high voltage, do not open the control box cover for ten minutes after the safety breaker is switched off.
After the box is opened, measure the voltages of the points shown right main circuit capacitor with a tester and confirm that the voltages are not higher than DC50 V.
Do not touch live parts when carrying out this work
[Design standard using period]
In case of using over the design
May cause ignition, injury from


DAIKIN AIRCONDITIONING INDIA PVT.LTD.
RIICO NEW INDUSTRIAL COMPLEX, NEEMRANA, RAJASTHAN, INDIA-301705
AIR CONDITIONER HEAT PUMP/COOLING ONLY
MODEL FCFQ100CV16 INDOOR UNIT
POWER SUPPLY 230 V 1~ PH 50 Hz
INPUT COOLING 225 W - W
FAN MOTOR PH QTY FLA W OUT
- - - - 1 - 1.7 - 106 -
MASS 25 kg
SER. NO. 0002592
MFG. DATE September-2026
MADE IN INDIA
SCAN FOR MANUAL
SCAN FOR MFG
IS:1391(Part-2)
CM/L-8400163007
FOR DETAILS OF BIS CERTIFICATION PLEASE VISIT www.bis.gov.in
MFG:MANUFACTURING DETAIL
2P811882-1