


# B.M.S Room Split A/C ITR



\* Split A/C ITR

\* Copper pipe 3/8" / 1/4"

$$\rightarrow 0.5 + 0.7 + 8.95 + 3.3 + 1.4 = \underline{14.85}$$

\* Drain pipe with insulation 20 mm

$$\rightarrow 0.5 + 0.7 + 8.95 + 0.55 + 0.4 = \underline{11.1}$$

\* L Stand Normal — 1805

\* Drain pump motor — 1805

$$\text{* cable} \quad \text{---} \quad 1.1 + 0.7 + 8.95 + 3.3 + 2 = \underline{\underline{16.5}}$$

\* Installation

*Asmages*  
*Cherats*  
 02/01/2026

*RLO*



DAIKIN AIRCONDITIONING INDIA PVT. LTD.

Authorised Service Center

AEON AIRCONDITIONING SOLUTIONS

AEON HOUSE, SHOP NO. 6/7, BEHIND N CUBE CHINA TOWN

DR. AMBEDKAR ROAD, THANE W 400601 MAHARASHTRA. PHONE :- 02225370101 / 7900097007



PROJECT :- TCG - Megatron 4 Square - Walsad Pune.

Measurement Sheet

Sr. No.	Location	AC Type	Tonnage	Indoor Unit Details		Outdoor Unit Details		Copper in Rmt	Cable in Rmt	Cable to Rmt	ODU Stand
				Model No.	Sr. No.	Model No.	Sr. No.				
1	Server room	Split	1.0TR	FKL35UV16WA	0042152	RKL35UV16WA	0092947	13.5	15.5	11.6	1
2											
3											
4											
5											
6											
7											
8											

EXTRA ACTIVITY CARRIED OUT

CONDENSER	Stabilizer			TIMER	CASING CAPPING	CABLE TRAY	DRAIN INSULATION	DISMANTLING	RE-INSTALLATION
	3KVA	4KVA	5KVA						
						Drain Pump	118.6 RMT	H. Wall	Cassette
						1 NOS.			

For Customer Details:	TCG Megatron	Vendor Details:	AEON Air Conditioning Solutions
Sign:	<i>[Signature]</i>	Signature:	
Name:	Bharat. N. Magas	Technician Name:	Pamez Khan
Date:		Date:	29/12/2025

