



DAIKIN AIRCONDITIONING INDIA PVT. LTD.
Service Completion Certificate

1598

AEON AIRCONDITIONING SOLUTIONS

Office No. 108 & 109, Devashree Garden, Commercial Complex,
R.W. Swaant Marg, above Sheetal Dairy, Rutu Park, Thane - 400 601.
Mob.: 9322334107 / 9322334109

Subject :

Registration No.		Request Date		Service Engineer		Scheduled Date/Time		Service Order	
User: Blue Dart Express		Customer Address: Vile Parle		Base Address: Vile Parle		Daikin Invoice:		Dealer Invoice:	
Type		Model No		Manufacturing No.		Operation data (Ambient temp. °C)		Fault Diagnosed	
Outdoor unit /		RK35UV16V		0025673		HP / T		Power Failure	
Indoor unit		FTK35UV16V		0011799		Before repair		Phase Reverse	
Work Date		No. of S.E.		Work hours		Progress code		In door unit PCB Defective	
3		7		25		1-TR Daikin A1c		Out door PCB Defective	
Installation Done		Compressor manufacturing No.		Defective Compressor		Replacement Compressor		In door unit Fan Motor Defective	
Installed date		Warranty		AMC		Using with		Outdoor Fan Motor Defective	
Yes / No		Yes / No		Yes / No		Yes / No		Comp. taking High Current / Amp	
Service Engineer Remarks		Cooling Fine.		Signature		Total		Compressor Ground / Earth	
Name		Signature		Customer Impression about Service		a		Compressor Tripping due to High Temperature	
Customer Remarks		Signature		(Please rate on scale of 1 poor, 2, 3, 4 & 5 excellent)		b		Compressor tripping due to High Pressure	
Name		Signature		How is the behavior of visited engineer		c		Indoor Unit MgsW Defective	
				What is the level of your satisfaction		d		Outdoor Unit MgsW Defective	
				How is the explanation by Engineer		e		Indoor Unit Transformer Faulty	
						f		Out door Unit Transformer Faulty	
								Fault of swing Motor	
								Detect of Drain Pump	
								Expansion Valve Body / Motor Defective	
								Defective Temperature Sensor of Indoor Unit	
								Defective temperature Sensor of Outdoor Unit	
								Defective Current Sensor In Out door Unit	
								Gas Leakage at Indoor Unit	
								Gas Leakage at Outdoor Unit	
								Blower broken	
								Short Cycling of Air at Indoor Unit	
								Short Cycling of Air at Outdoor Unit	
								Defect in Drain piping System	
								Gas Leakage from Flare nut	
								Error in Transmission wiring	
								Product under capacity	
								Rat bite case	
								Less cooling problem due to dirty Airlifter	
								Remote setting changed	
								Clogged Condenser	
								Other - Pl. specify	
								Details of Repair Work Done	
								a Simple Repair	
								b Part Replaced	
								c Part Replaced	
								d Gas Charging done	
								e Routine Service - Wet	
								f Routine Service - DRY	

Daikin Customer Care : Missed Call or SMS <DAIKIN> to 92101 88999; Toll Free Number : 1860 180 3900 / 1800 102 9300; cs@daikinindia.com / www.daikinindia.com



1597



AEON AIRCONDITIONING SOLUTIONS
Office No. 108 & 109, Devashree Garden, Commercial Complex,
V. Sawaant Marg, above Sheetal Dairy, Rutu Park, Thane - 400 601
Mob.: 9322334107 / 9322334109

Subject :

Registration No.		Request Date		Service Engineer		Scheduled Date/Time		Service Order	
User: Blue Dart Express		Request Date: 3/7/25		Service Engineer: A2am		Scheduled Date/Time: 3/7/25		Service Order: 31725	
Customer Address: Vile Parle				Operation data (Ambient temp. °C)			Fault Diagnosed		
I Base Address: Vile Parle				Before repair			After repair		
Daikin Invoice: Date: SP / T °C				pslg/°C			pslg/°C		
Dealer Invoice: Date: Current °C				Amps °C			Amps °C		
Type		Model No		Manufacturing No.		Voltage		Volts	
Outdoor unit / Indoor unit		RKM35UV16U 0024783		FTKA35UV16U 0018815		Indoor temperature		Suction °C °C	
Work Date		No. of S.E.		Work hours		Progress code		Details of the Repair Work	
3/7/25								1. TR Daikin A/C installation done.	
Compressor manufacturing No.		Defective Compressor		Replacement Compressor		Work No / Parts No		Qty	
Installed date		Warranty		AMC		Using with Stabilizer Cut off		Fault location Phenomena code Error code	
Yes / No		Yes / No		Yes / No		Yes / No		Yes / No	
Service Engineer Remarks: Cooling fine.				Signature: [Signature]		Total		Billing Amount	
Customer Remarks: Ravi				Signature: [Signature]		Customer Impression about Service		a Simple Repair	
						(Please rate on scale of 1 poor, 2, 3, 4 & 5 excellent)		b Part Replaced	
						How is the behavior of visited engineer		c Part Repaired	
						What is the level of your satisfaction		d Gas Charging done	
						How is the explanation by Engineer		e Routine Service - Wet	
								f Routine Service - DRY	

Daikin Customer Care : Missed Call or SMS <DAIKIN> to 92101 88999 ; Toll Free Number : 1860 180 3900 / 1800 102 9300 ; cs@daiकिनdia.com / www.daiकिनdia.com

www.dalkinindia.com



1596

AEON AIRCONDITIONING SOLUTIONS

AEON AIRCONDITIONING SOLUTIONS
Office No. 108 & 109, Devashree Garden, Commercial Complex,
R.W. Swaant Marg, above Sheetal Dairy, Rutu Park, Thane - 400 601.
Mob.: 9322334107 / 9322334109

Subject :

Registration No.		Request Date		Service Engineer		Scheduled Date/Time		Service Order	
User: Blue Dart Express		Mobile: 42am		3/7/25				Fault Diagnosed	
Customer Address: Vile Parle		Base Address:		Operation data (Ambient temp. °C)		Power		Power Failure	
Daikin Invoice:		Date:		Before repair		After repair		Phase Reverse	
Dealer Invoice:		Date:		HP / T		pslg/		pslg/	
Type		Model No		Manufacturing No.		SP / T °C		pslg/°C	
Outdoor unit /		RKM 60UV16U		0034269		Current °C		Amps°C	
Indoor unit		MTKM 60UV16U		0001611		Voltage		Volts	
Work Date		No. of S.E.		Work hours		Progress code		Details of the Repair Work	
3		7		25		2. TR Daikin AC		Installation Done	
Compressor manufacturing No.		Defective Compressor		Replacement Compressor		Work No / Parts No		Qty	
Installed date		Warranty		AMC		Using with		Fault location	
		Yes / No		Yes / No		Yes / No		Yes / No	
Service Engineer Remarks		cooling fine.		Signature		Total		Billing Amount	
Customer Remarks		Ravi		Signature		Customer Impression about Service		a Simple Repair	
Name		Signature		Signature		(Please rate on scale of 1 poor, 2, 3, 4 & 5 excellent)		b Part Replaced	
						How is the behavior of visited engineer		c Part Repaired	
						What is the level of your satisfaction		d Gas Charging done	
						How is the explanation by Engineer		e Routine Service - Wet	
								f Routine Service - DRY	
								Details of Repair Work Done	
								✓	

Daikin Customer Care : Missed Call or SMS <DAIKIN> to 92101 88999 ; Toll Free Number : 1860 180 3900 / 1800 102 9300 ; cs@daikinindia.com / www.daikinindia.com

DAIKIN

DAIKIN AIRCONDITIONING INDIA PVT. LTD.
Service Completion Certificate

1595



AEON AIRCONDITIONING SOLUTIONS
Office No. 108 & 109, Devashree Garden, Commercial Complex,
R.W. Swant Marg, above Sheetal Dairy, Ritu Park, Thane - 400 601.
Mob.: 9322334107 / 9322334109

Subject :

Registration No.		Request Date		Service Engineer		Scheduled Date/Time		Service Order	
				A2am		3/7/25			
User: Blue Dart Express				Mobile:		Fault Diagnosed			
Customer Address:						✓			
Base Address: Vile Parle.									
Daikin Invoice:		Date:		SP / T °C		pslg/°C		pslg/°C	
Dealer Invoice:		Date:		Current °C		Amps °C		Amps °C	
Type	Model No	Manufacturing No.		Voltage		Volts		Volts	
Outdoor unit /	RXM60UV16U	0033836		Indoor temperature					
Indoor unit	MTRM60UV16U	0001557		Suction		°C		°C	
Work Date	No. of S.E.	Work hours	Progress code	Discharge		°C		°C	
3				Outdoor temperature					
7				Suction		°C		°C	
25				Discharge		°C		°C	
Details of the Repair Work				Work No / Parts No		Qty		Billing Amount	
2-TR Daikin ALC									
Installation done.									
Compressor manufacturing No.		Defective Compressor		Replacement Compressor					
Installed date	Warranty	AMC	Using with	Fault location	Phenomena code	Error code			
	Yes / No	Yes / No	Stabilizer Cut off						
Service Engineer Remarks				Cooling Fine.					
Name: Ansul				Signature: [Signature]					
Customer Remarks				Signature: [Signature]					
Name: Ravi				Signature: [Signature]					
Customer Impression about Service						Details of Repair Work Done			
(Please rate on scale of 1 poor, 2, 3, 4 & 5 excellent)						a Simple Repair			
How is the behavior of visited engineer						b Part Replaced			
What is the level of your satisfaction						c Part Repaired			
How is the explanation by Engineer						d Gas Charging done			
						e Routine Service - Wet			
						f Routine Service - DRY			

Daikin Customer Care : Missed Call or SMS <DAIKIN> to 92101 88999 ; Toll Free Number : 1860 180 3900 / 1800 102 9300 ; cs@daikinindia.com / www.daikinindia.com

DAIKIN

DAIKIN AIRCONDITIONING INDIA PVT. LTD.
Service Completion Certificate



AEON AIRCONDITIONING SOLUTIONS
Office No. 108 & 109, Devashree Garden, Commercial Complex,
R.W. Swaant Marg, above Sheetal Dairy, Ratu Park, Thane - 400 601.
Mob.: 9322334107 / 9322334109

Subject :

1594

Registration No.		Request Date		Service Engineer		Scheduled Date/Time		Service Order	
				A2am		31/7/25			
User: Blue Dart Express				Mobile:		Fault Diagnosed			
Customer Address:									
Base Address: Vile Parle.									
Daikin Invoice:				Date:		Operation data (Ambient temp. °C)			
Dealer Invoice:				Date:					
Type				Model No		Manufacturing No.			
Outdoor unit / Indoor unit				RTU 60UV16U		0034237			
Work Date				No. of S.E.		Work hours		Progress code	
3				7		25			
Details of the Repair Work				2. TR Daikin A/C		installation done			
Compressor manufacturing No.				Defective Compressor		Replacement Compressor			
Installed date				Warranty		AMC			
Yes / No				Yes / No		Yes / No			
Service Engineer Remarks				Cooling Fine.					
Name				Signature					
Customer Remarks				Signature					
Name				Signature					
Customer Impression about Service				(Please rate on scale of 1 poor, 2, 3, 4 & 5 excellent)					
How is the behavior of visited engineer									
What is the level of your satisfaction									
How is the explanation by Engineer									
a Simple Repair									
b Part Replaced									
c Part Repaired									
d Gas Charging done									
e Routine Service - Wet									
f Routine Service - DRY									
Details of Repair Work Done									

DAIKIN

DAIKIN AIRCONDITIONING INDIA PVT. LTD.

Service Completion Certificate


AEON AIRCONDITIONING SOLUTIONS

 Office No. 108 & 109, Devashree Garden, Commercial Complex,
 R.W. Swaant Marg, above Sheetal Dairy, Ritu Park, Thane - 400 601.
 Mob.: 9322334107 / 9322334109

Subject :

1593

Registration No.		Request Date		Service Engineer		Scheduled Date/Time		Service Order	
				Azam		3/7/25			
User : Blue Dayt Express. Mobile :				Operation data (Ambient temp. °C)				Fault Diagnosed	
Customer Address :								✓	
I Base Address : Vile Parle									
Daikin Invoice :				Date :					
Dealer Invoice :				Date :					
Type	Model No		Manufacturing No.		HP / T		psig/	psig/	
Outdoor unit /	RKA 60UV16V		0034259		SP / T °C		psig/°C	psig/°C	
Indoor unit	MTJ24 60UV16		0001258		Current °C		Amps°C	Amps°C	
Work Date	No. of S.E.	Work hours	Progress code	Details of the Repair Work		Voltage	Volts	Volts	
3				2-TR Daikin A/C		Indoor temperature			
7				Installation Done.		Suction °C °C			
25						Discharge °C °C			
Compressor manufacturing No.				Defective Compressor		Replacement Compressor			
Installed date	Warranty	AMC	Using with	Fault location	Phenomena code	Error code			
	Yes / No	Yes / No	Stabilizer Cut off						
Service Engineer Remarks				Cooling fine.		Work No / Parts No		Qty	Billing Amount
Name				Signature		Total			
Customer Remarks				Signature		Customer Impression about Service			
Name				Signature		(Please rate on scale of 1 poor, 2, 3, 4 & 5 excellent)			
						How is the behavior of visited engineer			
						What is the level of your satisfaction			
						How is the explanation by Engineer			
						a Simple Repair			
						b Part Replaced			
						c Part Repaired			
						d Gas Charging done			
						e Routine Service - Wet			
						f Routine Service - DRY			
						Details of Repair Work Done		✓	

Daikin Customer Care : Missed Call or SMS <DAIKIN> to 92101 88999 ; Toll Free Number : 1860 180 3900 / 1800 102 0300 ; cs@daikinindia.com / www.daikinindia.com

DAIKIN AIRCONDITIONING INDIA PVT. LTD.
Service Completion Certificate

1592



AEON AIRCONDITIONING SOLUTIONS
Office No. 108 & 109, Devashree Garden, Commercial Complex,
W. Sawaant Marg, above Sheetal Dairy, Rutu Park, Thane - 400 601
Mob.: 9322334107 / 9322334109

Subject :

[illegible]

Daikin Customer Care : Missed Call or SMS to 92101 88999 ; Toll Free Number : 1860 180 3900 / 1800 102 9300 ; cs@daiknindia.com / www.daiknindia.com

DAIKIN

DAIKIN AIRCONDITIONING INDIA PVT. LTD.

Authorised Service Center

AEON AIRCONDITIONING SOLUTIONS

AEON HOUSE, SHOP NO. 6/7, BEHIND N CUBE CHINA TOWN

DR. AMBEDKAR ROAD, THANE W 400601 MAHARASHTRA. PHONE :- 02225370101 / 7900097007



PROJECT:- Blue Dayt Express Vile parle

Measurement Sheet

Sr. No.	Location	AC Type	Tonnage	Indoor Unit Details		Outdoor Unit Details		Copper In Rmt	Cable In Rmt	Drain In Rmt	ODU Stand
				Model No.	Sr. No.	Model No.	Sr. No.				
1	Work Area	Split 2TR	MTKM60U	0001615	RKM60U	0033959		10	12	10	—
2	Work Area	Split 2TR	MTKM60U	0001258	RKM60U	0034259		9	11	12	—
3	Work Area	Split 2TR	MTKM60U	0001697	RKM60U	0034237		10	12	8	—
4	Work Area	Split 2TR	MTKM60U	0001557	RKM60U	0033896		8	10	12	—
5	Work Area	Split 2TR	MTKM60U	0001611	RKM60U	0034269		6	8	10	—
6	Server	Split 1TR	ETKM35U	0018815	RKM35U	0024783		12	14	12	—
7	Reception	Split 1TR	ETKM35U	0011799	RKM35U	0025673		10	12	4	—
8											

EXTRA ACTIVITY CARRIED OUT

CIVIL WORK	Stabilizer			TIMER	CASING CAPPING	CABLE TRAY	GAS CHARGING	DISMENTALING		RE-INSTALLATION
	3KVA	4KVA	5KVA					Hi Wall	Cassette	
								7 A/C		

OTHERS

lifting and shifting

For Customer Details:

Sign:

[Signature]


Name:

Ravi

Date:

3/7/25

Stamp:



Vendor Details:

Signature:

[Signature]

Technician Name:

Azam

Date:

3/7/25